

Oneida Tribe of Indians of Wisconsin

ZONING DEPARTMENT

Location:

N7332 Water Circle Place
Oneida, WI 54155

**Mailing Address:**

P.O. Box 365
Oneida, WI 54155-0365

Office: (920) 869-1600

Toll Free: (800) 236-2868

Fax: (920) 869-1610

November 18, 2013

Mr. Bruce King

Oneida Seven Generation Corporation

Subject: 1201 O'Hare Boulevard Property

Fire Inspection

Upon conducting a fire inspection on November 14, 2012 it was noticed that there was an operation being conducted which required the use of an open flame device. After completing the fire inspection, a discussion regarding the use of each item was had and pictures about the project were taken. It was also made known that some of the information and or design was of a proprietary nature.

The following sections from both NFPA 1 and NFPA 101 (National Fire Protection Association) regulate the change in use, open flames, wall separation requirements for mix uses

Change in Use:

NFPA 1 and NFPA 101 set standards for occupancies when they are changed within a structure. Both NFPA 1: 10.3.4, NFPA 101:4.6.12 and 43.7 address the change in use or occupancy

Open Flame Devices:

NFPA 1 Sets standards for the use of Open Flame Devices

NFPA 1: 10.11.8.1 addresses the use of open flame devices as permits by the AHJ

NFPA 1: 10.11.9 addresses the authority of the AHJ to require the immediate discontinuation of the open flame device.

Wall Separation Requirements:

NFPA 1

Oneida Tribe of Indians of Wisconsin

ZONING DEPARTMENT

Table 6.1.14.4.1 (b) part 2: the required fire wall separation between industrial and business occupancy is a 2-hr rated wall.

Summary

The use of the open flame devices shall be discontinued until all of the following is completed

- A Certificate of Occupancy is granted
- The UL listing of the device is reported
- The wall separating the Industrial Occupancy of the building from the Business Occupancy has a 2 hour rating for both horizontal and vertical walls.